

Generation of diurnal variation for influent data for dynamic simulation

Motivation

Design guidelines for activated sludge (AS) plants that are based on static models such as the German DWA A131 (2000) are common practice in many countries. Over the last decades numerical models for activated sludge (AS) plants (Henze et al., 2000) have been becoming more popular and are generally used as a powerful tool to increase the detailed knowledge on the process and system behaviour, for optimisation studies (e.g. performance evaluation, operational optimisation, controller design, and conceptual process design), for training and teaching, and for model-based process control (Germaey et al., 2004; Langergraber et al., 2004). Especially in German speaking countries numerical models are hardly used in the design process (Alex et al., 2007). The use of numerical models enables fine tuning of the plant design by including the evaluation of the dynamic behaviour as well as the design of control strategies.

To use dynamic simulation for the optimisation of design, diurnal variation of the influent data is required. If there are only few or no measurements available these influent data have to be generated. Germaey et al. (2006) presented a method that is based on the pollutant load from each person in a catchment and considers also the layout of the sewer network. In this paper a simple approach to model diurnal variations that uses input data derived from the design of AS plants is presented. The aim is not to produce the exact diurnal variations that can be expected in reality, but to generate **input data for dynamic simulations with a realistic pattern for flow and concentrations in the case that no measured data are available.**

Model approach

The overall wastewater flows and concentrations are modeled as sum of different wastewater streams (infiltration water, nitrogen rich wastewater – i.e. urine with flush water, and domestic wastewater without urine). Rainwater is not considered in this paper but can be incorporated easily.

Table 1. Form parameters for different plant sizes

| PE | 5000 | 10000 | 20000 | 50000 | 100000 | 200000 | 400000 | Generic |
|------------------------|-------|-------|-------|-------|--------|--------|--------|---------|
| fQ _{min} [-] | 0.56 | 0.58 | 0.60 | 0.63 | 0.66 | 0.68 | 0.70 | yes |
| t _{min} [h] | 3.37 | 3.76 | 4.15 | 4.66 | 5.05 | 5.44 | 5.84 | yes |
| fQ _{max} [-] | 1.35 | 1.32 | 1.30 | 1.26 | 1.24 | 1.21 | 1.19 | no |
| t _{max} [h] | 11.30 | 11.56 | 11.81 | 12.15 | 12.41 | 12.67 | 12.92 | yes |
| fN _{max} [-] | 1.60 | 1.60 | 1.60 | 1.60 | 1.60 | 1.60 | 1.60 | no |
| f _{min,U} [-] | 0.18 | 0.24 | 0.30 | 0.38 | 0.44 | 0.49 | 0.55 | yes |
| dtN [h] | 0.78 | 0.78 | 0.78 | 0.78 | 0.78 | 0.78 | 0.78 | yes |
| tPlug [h] | 0.49 | 0.77 | 1.06 | 1.44 | 1.73 | 2.01 | 2.30 | no |

Summary and conclusion

A simple method is presented to generate diurnal variations for input data for dynamic simulations in the case of no measured data are available. The input data required for the model are either available from the design process or simple to collect are:

- the daily influent dry weather flow and mean concentrations of COD, TKN and TP,
- the flow and concentrations of infiltration water and urine (with flush water),
- and the form parameters as summarised in Table 1 which are not generic (only fQ_{max}, fN_{max} and tPlug).

References

- Alex, J., Wichern, M., Hall, N., Sperrig, V., Ahnert, M., Frehmann, T., Hobus, I., Langergraber, G., Plattes, M., Winkler, S., Woerner, D. (2007): A method to use dynamic simulation in compliance to stationary design rules to refine WWTP planning. Poster presentation at the 10th IWA Specialised Conference on "Design, Operation and Economics of Large Wastewater Treatment Plants", 10-13 September 2007, Vienna, Austria, this conference.
- DWA A131 (2000): ATV-DVWK Arbeitsblatt A131: Bemessungen von einstufigen Belebungsanlagen ab 5000 EW. DWA, Hennef, Germany [in German].
- Germaey, K.V., van Loosdrecht, M.C.M., Henze, M., Lind, M., Jørgensen, S.B. (2004): Activated sludge wastewater treatment plant modelling and simulation: state of the art. Environ Model Softw 19(9): 763-783.
- Germaey, K.V., Rosen, C., Jeppsson, U. (2006): WWTP dynamic disturbance modelling – an essential module for long-term benchmarking development. Water Sci Technol 53(4-5): 225-234.
- Henze M., Gujer W., Mino T. and van Loosdrecht M. (2000): Activated sludge models ASM1, ASM2, ASM2D and ASM3. IWA Scientific and Technical Report No.9. IWA Publishing, London, UK.
- Langergraber, G., Rieger, L., Winkler, S., Alex, J., Wiese, J., Owerdeck, C., Ahnert, M., Simon, J., Maurer, M. (2004): A guideline for simulation studies of wastewater treatment plants. Water Sci Technol 50(7): 131-138.

Different wastewater streams are assumed to have **constant concentrations** and **variable flows**. Beside flow the concentrations for **COD, TKN and TP are considered**.


For the mathematical formulation of the periodic patterns **2nd-order Fourier series** are used. The three sources are mixed and finally moved through a plug-flow tank to describe the load retention in large sewer systems and optionally the primary clarifier.

Methods


To describe the periodic flow pattern, four parameters are used: The minimum and maximum flow, Q_{min} and Q_{max} (described by the form parameters **fQ_{min}** and **fQ_{max}**) and the times when they occur, **t_{min}** and **t_{max}**, respectively. To describe nitrogen dynamics the following parameters are used: **fN_{max}** = ratio CTKN,max/CTKN,mean, **f_{min,U}** = % fraction of minimum urine flow rate to mean urine flow rate, and **dtN** TKN minimum and maximum relative to minimum and maximum of flow. Finally the hydraulic retention time of the water in the sewer system and primary clarifier **tPlug** is defined.

As a first step of implementation flows and concentrations have been fitted to measured data to derive general form parameters. Therefore measured data (flow, COD and TKN from two-hour composite samples from the influent of AS tanks) have been collected in total for more than 20 AS plants in Austria and Germany with plant sizes between 4'000 and 600'000 PE. The input data and the form parameters have then been used to generate the diurnal variation data.


Based on the estimation of the form parameters for all data sets their dependence from the size of the AS plant (expressed as PE) has been investigated. A set of equations has been derived from correlations analysis for all form parameters (not shown). No dependency from the plant size could be found for fN_{max} and dtN; the parameters describing the behaviour of the TKN maximum. Table 1 gives calculated values for the form parameters using the equations derived for plant sizes




Model approach for periodic dry weather influent



Model fitted to one example data set (The form parameters (Q_{min}, t_{min}, Q_{max}, t_{max}, fN_{max}, f_{min,U}, dtN and tPlug) have been estimated by fitting the equations to the measured data of flow, COD and TKN. The total flow has been fitted to measured flow data. The Figure compares the measured and modelled flow and concentrations of COD and TKN for an AS plant. In general, a good fit to the measured data could be observed.)



Model parameter as function of PE (two examples, left: ratio of maximum flow rate/mean flow rate, right: time of minimum flow rate)



Typical flow pattern (function of PE)

- G. Langergraber, N. Weissenbacher** Institute of Sanitary Engineering and Water Pollution Control, University of Natural Resources and Applied Life Sciences, Vienna, Austria.
- J. Alex** ifak, Institut f. Automation und Kommunikation, Barleben, Germany.
- D. Woerner** iaks - Ingenieurbüro für Abfluss – Kläranlagen – Steuerung GmbH, Sonthofen, Germany.
- M. Ahnert**, Institute for Urban Water Management, TU Dresden, 01069 Dresden, Germany.
- T. Frehmann** Emschergenossenschaft/Lippeverband, Essen, Germany.
- N. Halft** Department of Environmental Engineering, RWTH Aachen, Germany.
- I. Hobus** WiW - Wupperverbandsgesellschaft für integrale Wasserwirtschaft mbH, Wuppertal, Germany.
- M. Plattes** Centre de Ressources des Technologies pour l'Environnement (CRTE), CRP Henri Tudor, Luxembourg.
- V. Sperrig** Institute of Sanitary Engineering and Waste Management (ISAH), University of Hanover, Hanover, Germany.
- S. Winkler** Vienna University of Technology, Institute of Water Quality, Resources and Waste Management, Vienna, Austria.

Part of
Hochschulgruppe Simulation
a group of researchers from Germany, Austria,
Luxembourg, Poland, the Netherlands and
Switzerland

<http://www.HSGSim.org>